

ตารางแสดงค่าพารามิเตอร์ระบบบำบัดน้ำเสีย (ค่าBOD) ก่อนและหลังการปรับปรุง

		Parameter															
		pH		T.D.S.		SS		Set. S		BOD		OIL & GREASE		Sulfide		TKN	
Standard		5.0 - 9.0		500		30		0.5		20		20		1		35	
Time		In	Eff	In	Eff	In	Eff	In	Eff	In	Eff	In	Eff	In	Eff	In	Eff
1	10-Oct-60	7.14	6.86	510.0	138.0	45.0	12.0	4.0	0.5	206.0	31.0	9.0	5.0	7.5	0.0	28.0	3.0
2	7-Nov-60	6.88	6.62	680.0	216.0	2780.0	19.0	250.0	0.5	850.0	25.0	94.0	5.0	10.0	0.0	76.0	8.0
3	12-Dec-60	6.23	6.31	880.0	257.0	3300.0	9.0	0.5	0.5	1730.0	7.0	71.0	5.0	6.0	0.0	69.0	2.0
4	9-Jan-60	6.43	6.56	380.0	206.0	3040.0	13.0	120.0	0.5	1450.0	28.0	55.0	5.0	6.0	0.0	90.0	8.0
5	13-Feb-61	5.48	6.51	1100.0	256.0	2460.0	12.0	500.0	0.5	4800.0	32.0	69.0	5.0	31.6	0.0	112.0	5.0
6	13-Mar-61	6.41	6.42	445.0	164.0	1020.0	8.0	60.0	0.5	1140.0	14.0	65.0	5.0	26.0	0.0	84.0	9.0
7	10-Apr-61	5.48	6.48	610.0	140.0	6320.0	18.0	150.0	0.5	2090.0	13.0	132.0	5.0	20.0	0.0	392.0	7.0
8	8-May-61	6.57	6.42	230.0	200.0	1660.0	20.0	25.0	0.5	955.0	24.0	81.0	5.0	16.8	0.0	157.0	8.0
9	5-Jun-61	6.56	6.35	710.0	485.0	2180.0	10.0	100.0	0.5	886.0	3.0	70.0	5.0	42.4	0.0	90.0	12.0
10	3-Jul-61	6.89	6.82	550.0	356.0	1270.0	12.0	50.0	0.5	400.0	15.0	41.0	5.0	32.4	0.0	67.0	12.0
11	7-Aug-61	6.65	7.06	400.0	228.0	6500.0	22.0	180.0	0.5	1050.0	20.0	71.0	5.0	76.0	0.0	420.0	12.0
12	4-Sep-61	6.73	6.59	570.0	448.0	5290.0	30.0	70.0	0.5	578.0	13.0	78.0	5.0	15.4	0.0	84.0	2.0

ตารางค่า พารามิเตอร์ในระบบบำบัดน้ำเสีย ก่อนปรับปรุง

		Parameter															
		pH		T.D.S.		SS		Set. S		BOD		OIL & GREASE		Sulfide		TKN	
Standard		5.0 - 9.0		500		30		0.5		20		20		1		35	
Time		In	Eff	In	Eff	In	Eff	In	Eff	In	Eff	In	Eff	In	Eff	In	Eff
1	9-Oct-18	6.74	6.6	510.0	188.0	5040.0	24.0	130.0	0.5	370.0	18.0	81.0	5.0	50.0	0.0	106.0	5.0
2	6-Nov-18	7.09	7.09	845.0	628.0	105.0	56.0	1.5	0.5	234.0	32.0	10.0	5.0	5.3	0.0	70.0	10.0
3	4-Dec-18	6.65	7.06	470.0	236.0	2140.0	8.0	100.0	0.5	1035.0	3.0	76.0	5.0	8.8	0.0	95.0	3.0
4	8-Jan-19	6.77	6.62	420.0	248.0	700.0	16.0	60.0	0.5	343.0	17.0	27.0	5.0	11.8	0.0	151.0	15.0
5	5-Feb-19	6.69	6.43	970.0	124.0	2230.0	20.0	40.0	0.5	2100.0	4.0	99.0	5.0	49.6	0.0	106.0	5.0
6	5-Mar-19	7.08	6.83	420.0	214.0	970.0	50.0	80.0	0.5	1620.0	11.0	33.0	5.0	16.4	0.0	67.0	7.0
7	2-Apr-19	6.95	6.82	520.0	466.0	5360.0	7.0	1000.0	0.5	1440.0	9.0	90.0	5.0	35.2	0.0	154.0	13.0
8	7-May-19	6.99	6.80	390.0	450.0	1320.0	28.0	40.0	0.5	1200.0	18.0	33.0	5.0	14.2	0.0	123.0	26.0
9	4-Jun-19	6.86	6.81	620.0	248.0	355.0	12.0	11.0	0.5	132.0	12.0	6.0	5.0	5.6	0.0	70.0	12.0
10	2-Jul-19	7.01	6.88	545.0	170.0	60.0	13.0	0.5	0.5	190.0	18.0	8.0	5.0	9.1	0.0	67.0	12.0
11	6-Aug-19	8.53	7.22	710.0	342.0	320.0	62.0	1.0	0.5	144.0	38.0	11.0	5.0	26.4	0.0	50.0	12.0
12	10-Sep-19	6.50	6.10	495.0	444.0	155.0	16.0	5.0	0.5	230.0	14.0	5.0	5.0	6.0	0.0	55.0	12.0

ตารางค่า พารามิเตอร์ในระบบบำบัดน้ำเสีย หลังปรับปรุง

ตารางแสดงค่าพารามิเตอร์ระบบบำบัดน้ำเสีย (ค่าBOD) ก่อนและหลังการปรับปรุง

